

CITY OF WALLIS

COMMERCIAL SAFETY INSPECTION

- Type of business that will occupy the building (may have to comply with Fire Code)
- Fire Extinguisher (one 5 pound for every 3,000 square feet)
- No open spaces in the electrical panel
- All plugs in wet area must be GFCI protected
- Ceiling tiles must be in good condition
- Post address (numbers only) must be placed on the building (4" inches tall).
- All outlets must have protective covers
- All light fixtures must have covers

INSPECCION DE SEGURIDAD COMERCIAL

- Tipo de negocio que ocupan el edificio (que cumpla con el código de fuego)
- No hay espacios abiertos en el panel eléctrico
- Todos los enchufes en zona húmeda deben ser protegido por GFCI
- Azulejos de techo deben estar en buenas condiciones
- Dirección (solo números) de correos se colocaran en el edificio (4" pulgadas de alto)
- Todos los enchufes de electricidad deben estar cubiertos
- Todos las lámparas deben estar cubiertos
- Extintor de incendios (mínimo de 5 libras par cada 3 mil pies cuadrados)